


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.822	7,4	540	208	7,9	40	3	93	99
2	8.770								
3	8.713								
4	8.253	7,3	436	300	8,5	37	13	92	96
5	9.427	7,5	422	300	7,9	34	12	92	96
6	9.767	7,4	501	300	7,9	33	2	93	99
7	8.959	7,5	403	306	8,3	35	13	91	96
8	8.958	7,5	535	280	8,5	30	3	94	99
9	8.942								
10	11.117								
11	7.167								
12	8.209	7,2	672	480	7,9	34	10	95	98
13	8.956	7,5	556	360	7,9	33	10	94	97
14	8.155	7,4	462	275	8,2	28	8	94	97
15	7.675	7,4	534	303	8,4	30	3	94	99
16	8.686								
17	8.881								
18	10.268	7,5	626	380	7,3	29	6	95	98
19	9.708	7,1	487	360	6,9	23	9	95	98
20	9.587	7,5	546	311	7,3	23	2	96	99
21	9.985	7,7	540	145	8,5	47	24	91	83
22	9.591	7,6	605	281	8,6	32	3	95	99
23	9.527								
24	9.397								
25	10.970	7,6	659	460	8,2	36	3	95	99
26	10.850	7,7	522	440	8,6	35	14	93	97
27	11.150	7,7	395	187	7,9	39	3	90	98
28	10.175	7,4	619	252	7,7	29	6	95	98
29	9.913	7,7	632	313	8,0	46	8	93	97
30	10.143								
31	8.931								
MED	9.344	7,5	535	312	8,0	34	8	94	97
MIN	7.167	7,1	395	145	6,9	23	2	90	83
MAX	11.150	7,7	672	480	8,6	47	24	96	99
TOTAL	289.652	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Octubre'15



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.042	7,6	426	232	7,1	47	3	89	99
2	5.255								
3	5.233								
4	5.773	7,4	675	200	7,2	35	10	95	95
5	5.138	7,5	571	400	7,5	33	11	94	97
6	5.042	7,5	440	189	7,3	51	4	89	98
7	5.403	7,6	474	333	7,2	35	8	93	98
8	4.143	7,4	421	256	7,4	38	4	91	98
9	5.679								
10	8.863								
11	6.626								
12	6.861	7,6	470	480	7,2	32	13	93	97
13	5.750	7,7	367	360	7,5	34	11	91	97
14	5.549	7,4	404	275	7,8	34	9	92	97
15	4.643	7,4	530	303	7,7	23	2	96	99
16	5.086								
17	8.063								
18	10.021	7,6	296	160	7,2	17	6	94	96
19	9.113	6,9	305	200	6,5	29	7	90	97
20	5.843	7,5	548	195	7,0	22	2	96	99
21	5.042	7,3	1.126	220	7,8	15	10	99	95
22	4.724	7,7	1.253	367	7,8	24	4	98	99
23	5.154								
24	5.362								
25	6.249	7,7	538	320	7,3	27	9	95	97
26	7.734	7,9	306	180	7,1	36	14	88	92
27	9.806	7,5	1.250	156	7,3	36	5	97	97
28	5.378	7,4	513	177	7,1	21	3	96	98
29	4.841	8,0	504	207	7,6	31	2	94	99
30	4.738								
31	5.187								
MED	6.043	7,5	571	261	7,3	31	7	93	97
MIN	4.143	6,9	296	156	6,5	15	2	88	92
MAX	10.021	8,0	1.253	480	7,8	51	14	99	99
TOTAL	187.341	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Octubre'15

