


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.861	7,4	454	372	8,1	45	8	90	98
2	8.314	7,2	500	308	8,1	25	3	95	99
3	8.314								
4	7.836								
5	7.543	7,4	667	400	8,5	55	16	92	96
6	6.792	7,4	481	360	8,4	54	22	89	94
7	9.655	7,3	538	338	7,5	50	9	91	97
8	8.147	7,4	538	212	8,3	50	8	91	96
9	7.892	7,6	516	272	7,9	50	10	90	96
10	7.822								
11	8.078								
12	7.421	7,4	475	160	8,4	58	6	88	96
13	5.861	7,6	698	340	7,8	51	10	93	97
14	9.711	7,4	636	316	7,4	45	6	93	98
15	7.904	7,4	538	192	7,6	50	13	91	93
16	7.873	7,2	621	212	7,8	50	11	92	95
17	8.458								
18	8.332								
19	7.263	7,4	452		7,6	44		90	
20	8.341	7,4	462		8,2	40		91	
21	8.261	7,3	704		9,1	36		95	
22	8.194	7,3	668		9,1	33		95	
23	7.827	7,2	697		9,1	37		95	
24	8.302								
25	7.906								
26	7.149	7,3	570		7,5	55		90	
27	8.075	7,3	728		7,5	73		90	
28	8.334	7,1	731		8,4	44		94	
29	7.966	7,2	590		8,9	34		94	
30	7.980	7,2	634		9,2	31		95	
31	8.050								
MED	7.983	7,3	586	290	8,2	46	10	92	96
MIN	5.861	7,1	452	160	7,4	25	3	88	93
MAX	9.711	7,6	731	400	9,2	73	22	95	99
TOTAL	247.462	-	-	-	-	-	-	-	-

## Rendimientos EDAR El Torno - Julio'15



	<b>Caudal entrada</b>	<b>AGUA BRUTA</b>			<b>AGUA TRATADA</b>			<b>REND. ELIMINACION</b>	
		<b>pH</b>	<b>D.Q.O.</b>	<b>D.B.O.5</b>	<b>pH</b>	<b>D.Q.O.</b>	<b>D.B.O.5</b>	<b>D.Q.O.</b>	<b>D.B.O.5</b>
<b>Día</b>	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.559	7,5	738	402	7,5	27	8	96	98
2	8.233	7,4	800	497	7,4	14	2	98	100
3	8.207								
4	8.976								
5	9.645	7,6	915	340	7,6	34	11	96	97
6	8.156	7,3	1.141	460	8,0	34	12	97	97
7	9.049	7,5	1.104	538	7,7	23	3	98	99
8	9.459	7,5	1.104	414	7,5	28	5	97	99
9	9.339	7,5	1.179	719	7,5	35	3	97	100
10	9.307								
11	10.010								
12	9.282	7,6	680	180	7,5	41	7	94	96
13	9.280	7,7	545	300	7,6	37	9	93	97
14	9.348	7,6	697	308	7,7	36	4	95	99
15	9.193	7,5	1.104	203	7,9	30	18	97	91
16	9.122	7,6	570	197	7,9	35	6	94	97
17	10.303								
18	10.659								
19	10.056	7,3	583		7,3	37		94	
20	9.986	7,5	1.165		7,7	29		98	
21	9.976	7,4	1.062		7,8	33		97	
22	10.031	7,5	1.208		7,4	19		98	
23	10.215	7,4	1.198		7,4	29		98	
24	10.644								
25	10.642								
26	10.445	7,1	1.524		7,0	35		98	
27	9.908	7,5	760		7,6	46		94	
28	10.088	7,4	554		7,6	30		95	
29	10.751	7,3	372		7,4	30		92	
30	10.665	7,5	392		7,5	22		94	
31	10.725								
<b>MED</b>	9.621	7,4	882	380	7,6	31	7	96	97
<b>MIN</b>	6.559	7,1	372	180	7,0	14	2	92	91
<b>MAX</b>	10.751	7,7	1.524	719	8,0	46	18	98	100
<b>TOTAL</b>	298.259	-	-	-	-	-	-	-	-

## Rendimientos EDAR La Barrosa - Julio'15

