


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.900								
2	8.115								
3	8.154								
4	7.995								
5	7.910	7,4	800	480	8,2	53	11	93	98
6	8.575	7,5	680	400	8,5	47	22	93	95
7	8.507	7,4	739	419	8,4	58	6	92	99
8	8.376	7,7	850	442	8,5	53	33	94	93
9	8.305	7,4	721	388	8,3	55	11	92	97
10	8.513								
11	8.342								
12	9.703	7,4	848	500	8,6	58	10	93	98
13	6.345	7,4	610	400	7,7	466	268	24	33
14	8.068	7,3	908	479	7,5	436	217	52	55
15	8.993	7,4	718	398	6,9	372	122	48	69
16	8.282	7,5	677	308	7,1	320	140	53	55
17	8.652								
18	8.258								
19	7.552	7,4	576	420	8,0	112	52	81	88
20	8.279	7,5	896	560	7,8	122	50	86	91
21	8.034	7,4	655	351	8,0	126	32	81	91
22	8.156	7,3	776	385	7,9	123	44	84	89
23	8.195	7,6	561	277	8,3	100	35	82	87
24	8.163								
25	8.081								
26	9.095	7,2	598	340	7,8	71	27	88	92
27	8.525	7,6	609	280	9,0	39	15	94	95
28	8.481	7,6	626	255	8,3	50	4	92	98
29	8.444	7,5	741	356	8,6	33	3	96	99
30	8.195								
31									
MED	8.306	7,4	715	391	8,1	142	58	80	85
MIN	6.345	7,2	561	255	6,9	33	3	24	33
MAX	9.703	7,7	908	560	9,0	466	268	96	99
TOTAL	249.193	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Abril'15



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.290								
2	7.050								
3	7.720								
4	7.047								
5	6.424	7,5	520	300	7,2	42	17	92	94
6	5.436	7,5	618	360	7,5	34	21	95	94
7	5.423	7,6	515	162	7,4	26	5	95	97
8	4.770	7,8	549	245	7,0	26	18	95	93
9	4.708	7,6	555	245	7,4	37	5	93	98
10	4.948								
11	5.200								
12	4.913	7,5	715	400	7,1	27	24	96	94
13	4.721	7,5	740	380	7,4	37	14	95	96
14	4.635	7,5	478	203	7,5	31	6	93	97
15	4.996	7,5	656	200	7,9	33	28	95	86
16	4.620	7,5	533	173	7,4	31	4	94	98
17	4.994								
18	5.492								
19	5.300	7,3	395	140	7,2	28	14	93	90
20	4.625	7,5	496	320	7,3	35	15	93	95
21	4.721	7,6	516	170	7,7	32	5	94	97
22	4.961	7,7	435	291	7,7	31	21	93	93
23	4.434	7,8	754	278	7,2	32	3	96	99
24	5.277								
25	5.688								
26	10.398	7,4	345	140	7,5	39	19	89	86
27	5.237	7,6	563	240	7,6	23	8	96	96
28	4.707	7,7	442	204	7,1	23	1	95	100
29	4.743	7,7	479	181	7,4	28	2	94	99
30	5.263								
31									
MED	5.491	7,6	542	244	7,4	31	12	94	95
MIN	4.434	7,3	345	140	7,0	23	1	89	86
MAX	10.398	7,8	754	400	7,9	42	28	96	100
TOTAL	164.741	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Abril'15

