


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.705								
2	11.592	7,6	300	140	8,0	40	3	87	98
3	11.821	7,3	401	280	7,3	27	9	93	97
4	10.342	7,5	598	295	8,0	42	16	93	95
5	9.964	7,4	584	267	7,7	48	5	92	98
6	10.195								
7	9.380								
8	8.879	7,5	812	460	7,5	50	19	94	96
9	9.646	7,4	680	360	7,6	46	19	93	95
10	9.594	7,2	587	316	7,4	44	5	93	98
11	9.689	7,4	557	236	7,5	44	12	92	95
12	9.592	7,5	658	305	7,7	42	3	94	99
13	9.548								
14	9.014								
15	8.664	7,5	826	460	7,8	39	20	95	96
16	9.163	7,5	694	440	8,0	44	11	94	98
17	9.260	7,5	685	256	7,6	65	7	91	97
18	9.247	7,6	732	325	7,3	47	13	94	96
19	9.331	7,5	719	342	7,6	42	7	94	98
20	9.331								
21	7.805								
22	9.228	7,5	769	520	7,8	41	12	95	98
23	9.066	7,5	655	440	7,4	40	6	94	99
24	8.853	7,6	706	281	7,4	48	4	93	99
25	8.990	7,5	712	355	7,6	41	5	94	99
26	8.982	7,7	601	289	8,0	42	8	93	97
27	9.147								
28	8.537								
29	8.224	7,7	643	440	7,6	68	14	89	97
30	8.900	7,5	806	480	7,8	59	18	93	96
31									
MED	9.390	7,5	654	347	7,6	46	10	93	97
MIN	7.805	7,2	300	140	7,3	27	3	87	95
MAX	11.821	7,7	826	520	8,0	68	20	95	99
TOTAL	281.688	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Noviembre'15



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.165								
2	9.565	7,6	237	120	6,8	22	9	91	92
3	8.005	7,4	250	120	7,3	15	7	94	94
4	5.445	7,6	400	238	7,2	27	14	93	94
5	4.671	7,3	306	102	7,1	23	1	92	99
6	4.280								
7	4.147								
8	3.835	7,4	254	180	7,5	26	7	90	96
9	3.820	7,4	351	140	7,3	20	11	94	92
10	3.562	7,4	252	60	6,7	18	1	93	98
11	3.989	7,3	317	150	6,8	17	5	95	96
12	3.424	7,6	326	93	7,0	17	1	95	99
13	3.607								
14	3.663								
15	3.605	7,8	322	240	7,4	17	6	95	98
16	3.412	7,8	455	200	7,6	22	6	95	97
17	3.471	7,9	427	76	7,4	17	1	96	99
18	3.288	7,8	265	74	7,2	23	2	91	98
19	3.190	7,9	250	94	7,4	16	2	94	98
20	3.850								
21	3.576								
22	4.695	7,7	282	220	7,3	24	7	92	97
23	3.521	7,9	502	120	7,3	28	9	94	93
24	3.332	7,8	302	89	7,5	29	1	91	99
25	2.879	7,6	282	74	7,0	25	2	91	97
26	3.146	7,7	216	78	7,9	31	4	86	94
27	3.164								
28	3.164								
29	3.086	7,7	322	240	7,2	28	8	91	97
30	2.852	7,8	312	140	7,5	35	13	89	91
MED	4.180	7,6	316	136	7,3	23	6	92	96
MIN	2.852	7,3	216	60	6,7	15	1	86	91
MAX	9.565	7,9	502	240	7,9	35	14	96	99
TOTAL	125.409	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Noviembre'15

