


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.383	7,6	616	270	7,3	40	8	93	97
2	8.410	7,5	787	366	7,5	42	10	95	97
3	8.602	7,6	741	296	7,5	41	5	94	98
4	8.300	7,6	441	244	7,7	25	4	94	98
5	8.247								
6	7.759								
7	8.602	7,0	711	310	7,8	39	8	94	97
8	8.031	7,4	591	288	7,9	38	8	94	97
9	8.199	7,3	659	238	7,7	51	12	92	95
10	7.215	7,5	814	440	7,6	42	13	95	97
11	9.025	7,6	771	320	9,2	43	12	94	96
12	8.410								
13	8.097								
14	8.020								
15	7.204	7,4	678	400	8,3	48	13	93	97
16	8.357	7,4	662	389	7,4	38	10	94	97
17	8.404	7,4	679	300	7,5	40	10	94	97
18	8.395	7,1	580	140	7,5	15	6	97	96
19	8.732								
20	8.157								
21	7.463	7,2	700	193	7,7	15	5	98	97
22	8.285	7,1	570	200	8,2	15	5	97	98
23	8.141	7,1	580	173	8,0	45	18	92	90
24	8.823	6,9	720	265	8,6	15	6	98	98
25	7.787	7,2	500	185	8,0	15	6	97	97
26	8.673								
27	8.181								
28	7.619	7,3	500	178	7,8	15	6	97	97
29	8.415	7,7	1.117	472	7,9	46	12	96	97
30	8.457	7,1	926	495	7,6	48	12	95	98
31	8.250	7,3	775	380	7,8	45	13	94	97
MED	8.214	7,3	687	297	7,8	35	9	95	97
MIN	7.204	6,9	441	140	7,3	15	4	92	90
MAX	9.025	7,7	1.117	495	9,2	51	18	98	98
TOTAL	254.643	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Agosto '16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	12.135	7,5	887	321	7,1	40	8	96	98
2	12.343	7,6	370	158	7,4	43	11	88	93
3	11.629	7,5	392	140	7,5	30	4	92	97
4	12.421	7,2	325	146	7,4	24	3	93	98
5	11.853								
6	11.716								
7	12.336	7,4	298	112	7,4	28	5	91	95
8	11.621	7,5	351	180	7,5	25	6	93	96
9	11.992	7,6	393	118	7,6	32	6	92	95
10	11.875	7,7	689	280	7,7	33	10	95	96
11	11.604	7,8	733	190	7,7	50	13	93	93
12	11.959								
13	11.665								
14	11.256								
15	11.603	7,4	542	360	7,3	40	10	93	97
16	11.877	7,4	545	305	7,4	32	8	94	97
17	12.130	7,5	708	320	7,3	48	14	93	96
18	12.049	7,2	440	118	7,5	21	8	95	93
19	12.452								
20	11.708								
21	11.147	7,1	455	124	7,7	15	5	97	96
22	11.829	7,3	495	168	7,7	22	9	96	95
23	11.381	7,2	285	101	7,7	27	11	91	89
24	10.019	7,1	440	162	7,2	26	12	94	93
25	10.952	7,3	445	147	7,5	15	7	97	95
26	10.924								
27	11.774								
28	11.150	7,0	730	274	7,8	15	5	98	98
29	11.389	7,5	692	305	7,7	46	11	93	96
30	10.825	7,0	566	256	7,4	36	8	94	97
31	10.508	7,2	509	300	7,4	31	8	94	97
MED	11.617	7,3	513	208	7,5	31	8	94	96
MIN	10.019	7,0	285	101	7,1	15	3	88	89
MAX	12.452	7,8	887	360	7,8	50	14	98	98
TOTAL	360.122	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Agosto'16

