


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.986								
2	6.968	7,5	659	320	7,4	45	10	93	97
3	8.014	7,6	720	350	7,4	51	13	93	96
4	8.195	7,6	612	333	7,6	43	10	93	97
5	8.249	7,3	815	400	7,7	41	9	95	98
6	8.240	7,2	830	445	7,5	51	10	94	98
7	8.160								
8	7.947								
9	8.421	7,6	562	450	7,7	50	16	91	96
10	7.393	7,6	711	430	7,7	48	15	93	97
11	8.654								
12	10.050								
13	9.760	7,6	457	260	7,6	31	8	93	97
14	8.782								
15	9.131								
16	5.632	7,7	751	460	7,7	51	17	93	96
17	7.657	7,6	683	380	7,6	44	14	93	96
18	7.804	7,6	605	321	7,6	43	11	93	97
19	7.781	7,5	678	338	7,4	41	10	94	97
20	7.761	7,6	712	365	7,4	41	9	94	97
21	8.151								
22	9.265								
23	10.651	7,8	372	180	7,5	43	11	88	94
24	9.675	7,5	502	280	7,3	24	6	95	98
25	8.427	7,8	590	276	7,5	37	9	94	97
26	8.285	7,5	793	403	7,5	30	6	96	99
27	8.003	7,4	784	395	7,4	45	10	94	98
28	8.153								
29	8.025								
30	7.856	7,6	751	390	7,7	39	9	95	98
31	7.803								
MED	8.254	7,5	662	357	7,5	42	11	93	97
MIN	5.632	7,2	372	180	7,3	24	6	88	94
MAX	10.651	7,8	830	460	7,7	51	17	96	99
TOTAL	255.879	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Octubre '16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.940								
2	6.632	7,4	391	170	7,6	31	9	92	95
3	6.085	7,7	372	230	7,6	31	10	92	96
4	7.228	7,7	844	444	7,6	31	7	96	98
5	6.866	7,4	949	444	7,4	34	8	96	98
6	6.997	7,2	573	271	7,4	32	7	94	97
7	6.535								
8	7.105								
9	6.364	7,4	763	390	7,6	42	11	95	97
10	6.303	7,4	627	420	7,7	41	10	93	98
11	4.878								
12	12.037								
13	8.350	7,2	344	190	7,3	32	7	91	96
14	7.043								
15	6.911								
16	5.724	7,1	654	380	7,2	80	22	88	94
17	6.655	7,0	536	320	7,4	99	24	82	92
18	6.109	7,0	546	299	7,4	80	21	85	93
19	6.097	7,3	1.092	566	7,4	63	15	94	97
20	5.117	7,4	978	469	7,4	59	14	94	97
21	7.223								
22	7.574								
23	9.892	7,5	400	220	7,4	29	5	93	98
24	7.182	7,2	475	250	7,0	25	5	95	98
25	5.375	7,5	577	248	7,4	27	6	95	98
26	5.383	7,6	324	177	7,4	27	5	92	97
27	4.386	7,6	373	177	7,4	36	8	90	96
28	4.826								
29	4.913								
30	4.744	7,8	433	190	7,4	33	6	92	97
31	4.598								
MED	6.583	7,4	592	308	7,4	44	11	92	96
MIN	4.386	7,0	324	170	7,0	25	5	82	92
MAX	12.037	7,8	1.092	566	7,7	99	24	96	98
TOTAL	204.072	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Octubre '16

