


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.786								
2	8.205								
3	8.981	6,9	968	360	7,3	113	9	88	98
4	9.569	7,0	825	360	7,3	84	5	90	99
5	9.338	7,1	1.170	600	7,1	96	22	92	96
6	8.875	7,0	1.143	571	7,2	83	14	93	98
7	8.829	7,1	950	450	7,1	68	12	93	97
8	9.167								
9	8.783								
10	11.829	7,2	596	320	7,5	78	10	87	97
11	9.914								
12	8.730	7,1	666	320	7,1	68	8	90	98
13	9.277	7,3	772	329	7,6	52	5	93	98
14	9.195	7,1	720	350	7,0	51	10	93	97
15	6.937								
16	8.249								
17	7.989	7,2	508	260	7,6	78	15	85	94
18	8.927	7,1	663	460	7,0	76	25	89	95
19	8.930	6,9	830	270	7,0	82	5	90	98
20	9.004	7,1	712	357	6,5	122	5	83	99
21	9.136	7,2	811	500	7,4	119	29	85	94
22	9.817								
23	8.266								
24	8.695	7,1	1.026	360	7,0	126	16	88	96
25	9.169	7,1	976	420	7,3	119	10	88	98
26	9.192	6,6	960	492	6,8	111	9	88	98
27	8.857	7,0	877	456	7,1	119	19	86	96
28	8.700	7,1	968	342	7,4	109	6	89	98
29	9.017								
30	8.379								
31	9.639								
MED	8.980	7,1	850	399	7,2	92	12	89	97
MIN	6.937	6,6	508	260	6,5	51	5	83	94
MAX	11.829	7,3	1.170	600	7,6	126	29	93	99
TOTAL	278.379	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Octubre'10



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.354								
2	6.884								
3	7.035	7,2	678	280	7,1	96	7	86	98
4	6.351	7,2	678	260	7,4	83	14	88	95
5	5.773	7,2	550	256	7,8	82	13	85	95
6	5.680	7,4	781	278	7,7	68	8	91	97
7	5.926	7,4	855	306	7,5	73	12	91	96
8	6.365								
9	8.375								
10	6.058	7,2	604	300	7,9	48	8	92	97
11	6.997								
12	6.567	7,1	855	400	7,1	66	10	92	97
13	6.161	7,3	601	381	7,9	64	6	89	98
14	5.748	7,1	529	289	7,1	65	9	88	97
15	5.972								
16	6.225								
17	6.172	7,2	737	300	7,6	58	8	92	97
18	5.679	7,3	603	320	8,0	68	14	89	96
19	5.673	7,1	601	388	7,8	72	4	88	99
20	5.527	7,2	844	319	7,3	98	7	88	98
21	5.638	7,3	894	311	7,2	117	6	87	98
22	5.762								
23	6.257								
24	6.002	7,1	819	320	7,5	98	7	88	98
25	5.201	7,4	827	340	7,8	105	5	87	99
26	5.163	7,3	861	406	7,7	104	10	88	97
27	4.912	7,3	811	288	7,7	110	5	86	98
28	5.121	7,4	894	307	8,2	103	5	88	99
29	5.186								
30	7.547								
31	7.293								
MED	6.116	7,2	738	318	7,6	83	8	89	97
MIN	4.912	7,1	529	256	7,1	48	4	85	95
MAX	8.375	7,4	894	406	8,2	117	14	92	99
TOTAL	189.604	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Octubre'10

