


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.403	7,0	1.043	267	7,5	117	24	89	91
2	9.834								
3	9.574								
4	9.063	7,2	1.291	600	7,4	117	16	91	97
5	10.351	6,9	1.291	460	7,1	117	20	91	96
6	9.733	7,5	1.026	558	7,4	117	33	89	94
7	9.538	7,1	894	393	7,4	119	27	87	93
8	9.491	7,1	935	329	7,3	113	25	88	92
9	10.002								
10	9.989								
11	9.702	7,5	1.043	340	7,2	117	13	89	96
12	11.148	7,1	1.043	360	7,1	117	31	89	91
13	11.763	6,9	1.043	442	7,3	117	18	89	96
14	12.269	6,9	993	414	7,2	117	26	88	94
15	11.256	7,2	1.796	414	7,3	121	31	93	93
16	10.780								
17	9.232								
18	8.876	7,0	952	480	7,3	114	18	88	96
19	9.854	7,0	952	400	7,2	113	13	88	97
20	10.001	7,4	910	457	7,7	121	22	87	95
21	9.902	7,2	918	450	7,3	121	25	87	94
22	9.769	7,3	877	269	7,5	117	13	87	95
23	10.090								
24	9.914								
25	9.097	6,9	960	400	7,2	121	13	87	97
26	9.937	6,9	910	400	7,4	119	18	87	96
27	10.426	6,8	877	331	7,5	122	15	86	95
28	10.402	6,8	976	521	7,2	111	6	89	99
29	9.871	6,8	976	514	7,2	111	12	89	98
30	9.920								
31	9.786								
MED	10.064	7,1	1.034	419	7,3	117	20	88	95
MIN	8.876	6,8	877	267	7,1	111	6	86	91
MAX	12.269	7,5	1.796	600	7,7	122	33	93	99
TOTAL	311.971	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Julio'10



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.920	7,0	861	313	7,1	121	16	86	95
2	7.824								
3	8.682								
4	8.395	7,3	1.291	540	7,7	117	16	91	97
5	8.089	7,1	844	380	7,2	116	14	86	96
6	8.143	7,3	902	443	7,4	116	29	87	93
7	8.261	7,2	1.043	500	7,2	111	8	89	98
8	8.713	7,0	1.043	450	7,1	108	20	90	96
9	9.889								
10	10.033								
11	9.596	7,4	1.026	300	7,5	117	17	89	94
12	9.114	7,1	885	400	7,5	106	17	88	96
13	9.269	7,1	1.010	314	7,4	111	22	89	93
14	8.338	7,2	1.043	425	7,2	117	18	89	96
15	8.541	7,2	877	306	7,3	110	22	87	93
16	8.513								
17	9.494								
18	8.951	7,2	877	360	7,2	114	14	87	96
19	8.964	7,2	910	360	7,2	121	12	87	97
20	8.239	7,4	786	275	7,4	117	19	85	93
21	9.496	7,1	861	375	7,2	111	10	87	97
22	9.176	7,1	902	329	7,5	103	12	89	96
23	9.765								
24	10.131								
25	10.100	7,0	927	360	7,3	115	17	88	95
26	9.932	7,1	885	360	7,3	113	12	87	97
27	9.831	7,0	943	471	7,0	109	6	88	99
28	9.828	7,0	902	571	7,1	100	14	89	98
29	9.015	7,0	844	425	7,2	112	12	87	97
30	10.318								
31	9.526								
MED	9.067	7,1	936	393	7,3	113	16	88	96
MIN	6.920	7,0	786	275	7,0	100	6	85	93
MAX	10.318	7,4	1.291	571	7,7	121	29	91	99
TOTAL	281.086	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Julio'10

