


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	12.435	7,5	736	280	7,1	109	28	85	90
2	13.874	7,7	960	370	7,4	136	14	86	96
3	10.267								
4	11.069								
5	11.595								
6	11.280	7,1	430	260	7,3	83	12	81	95
7	10.384								
8	10.635	7,5	885	320	7,1	114	19	87	94
9	10.185	7,3	869	538	7,3	125	33	86	94
10	10.995								
11	9.679								
12	9.411	7,4	794	260	7,3	192	47	76	82
13	9.898	7,4	885	340	7,5	174	50	80	85
14	10.041	7,3	927	371	7,3	179	50	81	87
15	9.999	7,6	811	313	7,5	162	40	80	87
16	10.427	7,4	918	286	7,4	152	38	83	87
17	9.693								
18	9.874								
19	11.605	7,5	604	140	7,3	147	17	76	88
20	11.294	7,6	1.117	440	7,5	119	15	89	97
21	10.152	7,3	1.543	650	7,4	119	30	92	95
22	10.885	8,1	1.382	350	7,4	115	13	92	96
23	13.157								
24	11.138								
25	9.607								
26	10.895	7,5	2.177	380	7,7	122	14	94	96
27	10.598	7,5	910	380	7,5	135	15	85	96
28	10.220	7,3	1.043	325	7,4	107	25	90	92
29	10.715	7,4	1.043	314	7,3	109	20	90	94
30	11.574								
31	11.614								
MED	10.813	7,5	1.002	351	7,4	135	27	85	92
MIN	9.411	7,1	430	140	7,1	83	12	76	82
MAX	13.874	8,1	2.177	650	7,7	192	50	94	97
TOTAL	335.197	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Diciembre'10



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.534	7,3	538	295	7,2	78	3	86	99
2	7.468	7,5	968	436	7,2	96	10	90	98
3	5.341								
4	5.008								
5	8.032								
6	8.239	7,4	397	260	7,2	113	18	71	93
7	7.360								
8	5.976	7,4	761	360	7,3	112	10	85	97
9	5.212	7,5	703	383	7,0	81	5	88	99
10	4.496								
11	4.256								
12	4.131	7,4	852	320	7,6	86	6	90	98
13	4.340	7,6	538	280	7,4	105	7	80	97
14	4.343	7,5	819	288	7,5	109	5	87	98
15	4.017	7,5	596	150	7,6	92	7	85	96
16	3.798	7,4	670	135	7,6	108	5	84	97
17	3.962								
18	7.783								
19	5.268	7,4	513	280	7,4	97	5	81	98
20	9.122	7,3	1.688	400	7,3	114	10	93	97
21	10.450	7,4	563	190	7,3	72	13	87	93
22	11.271	7,4	389	125	7,2	105	3	73	98
23	5.742								
24	4.906								
25	4.857								
26	4.252	7,6	885	340	7,4	87	7	90	98
27	4.629	7,5	728	340	7,5	82	10	89	97
28	4.215	7,5	645	160	7,4	81	3	87	98
29	4.186	7,5	770	283	7,5	97	5	87	98
30	4.397								
31	6.024								
MED	5.891	7,4	724	279	7,4	95	7	85	97
MIN	3.798	7,3	389	125	7,0	72	3	71	93
MAX	11.271	7,6	1.688	436	7,6	114	18	93	99
TOTAL	182.615	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Diciembre'10

