




E.D.A.R. El Torno

Febrero'11

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.794	8,0	952	257	7,8	109	4	89	98
2	10.379	7,6	1.125	267	7,6	109	6	90	98
3	10.225	7,4	960	207	8,0	109	3	89	99
4	10.398								
5	10.330								
6	10.063	7,4	960	512	7,8	86	5	91	99
7	9.848	7,7	952	364	7,7	117	9	88	98
8	9.973	7,6	952	407	7,6	114	10	88	98
9	10.024	7,5	786	238	7,7	113	12	86	95
10	9.874	7,7	844	281	7,4	114	9	86	97
11	10.636								
12	8.477								
13	10.359	7,5	1.001	300	7,5	114	10	89	97
14	10.807	7,5	960	300	7,3	109	23	89	92
15	11.849	7,1	827	275	7,0	88	7	89	97
16	11.600	7,5	952	529	7,3	109	14	89	97
17	12.746	7,5	952	500	7,5	106	28	89	94
18	11.995								
19	12.011								
20	12.865	7,5	728	320	7,7	88	11	88	97
21	10.920	7,3	1.001	420	7,5	114	24	89	94
22	11.301	7,3	960	429	7,8	81	12	92	97
23	10.743	8,0	1.092	583	7,8	106	13	90	98
24	10.724	7,4	985	593	7,8	117	21	88	96
25	10.365								
26	9.778								
27	9.901								
28	9.260	7,6	902	340	7,8	113	8	88	98
MED	10.652	7,5	942	375	7,6	106	12	89	97
MIN	8.477	7,1	728	207	7,0	81	3	86	92
MAX	12.865	8,0	1.125	593	8,0	117	28	92	99
TOTAL	298.244	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Febrero'11





E.D.A.R. La Barrosa

Febrero'11

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.253	7,9	720	150	8,3	92	6	87	96
2	3.973	7,7	844	100	7,9	93	4	89	96
3	4.696	7,7	529	281	7,9	113	3	79	99
4	4.172								
5	4.089								
6	4.307	7,8	463	222	8,1	74	4	84	98
7	4.503	7,2	637	255	7,1	92	9	86	96
8	4.228	7,5	621	195	8,1	91	6	85	97
9	4.167	7,7	778	194	8,1	85	5	89	97
10	4.215	7,7	521	205	8,2	84	7	84	97
11	4.355								
12	4.740								
13	5.437	7,7	943	260	7,8	91	5	90	98
14	4.986	7,6	836	340	7,4	97	10	88	97
15	11.607	7,2	422	94	7,0	66	3	84	96
16	13.876	7,2	770	267	7,5	97	6	87	98
17	8.886	7,6	861	481	8,5	101	11	88	98
18	6.746								
19	6.296								
20	5.817	7,7	521	260	8,1	100	10	81	96
21	5.661	7,7	803	340	7,7	96	11	88	97
22	5.281	7,7	869	250	7,7	98	7	89	97
23	4.899	7,7	877	313	7,7	104	8	88	97
24	5.247	7,7	819	450	7,9	98	3	88	99
25	4.949								
26	6.044								
27	6.207								
28	5.763	7,8	861	260	8,1	100	9	88	96
MED	5.693	7,6	721	259	7,8	93	7	86	97
MIN	3.973	7,2	422	94	7,0	66	3	79	96
MAX	13.876	7,9	943	481	8,5	113	11	90	99
TOTAL	159.400	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Febrero'11

