


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.508								
2	9.042								
3	8.610	7,3	533	240	7,3	75	10	86	96
4	9.462	7,5	838	260	7,7	92	18	89	93
5	9.469	7,4	763	106	7,8	93	7	88	93
6	10.218	7,4	734	211	7,6	80	6	89	97
7	10.162	7,4	629	168	7,9	72	4	89	98
8	10.345								
9	10.712								
10	9.155	7,0	689	400	7,7	95	10	86	98
11	9.217	7,5	934	400	7,7	104	10	89	98
12	10.358								
13	9.356	7,4	689	310	7,8	83	23	88	93
14	9.398	7,2	644	285	7,6	75	8	88	97
15	9.918								
16	9.350								
17	9.921	7,1	942	220	7,6	78	14	92	94
18	9.490	7,2	793	440	7,5	87	10	89	98
19	9.564	7,0	808	288	7,2	84	7	90	98
20	8.663	7,0	756	179	7,1	72	12	90	93
21	8.584	7,2	838	238	7,4	84	6	90	97
22	9.733								
23	8.050								
24	7.697	7,4	793	360	7,6	154	11	81	97
25	8.543	7,5	615	320	7,3	114	22	81	93
26	8.485	7,2	778	322	7,4	81	5	90	98
27	8.420	7,0	763	178	7,2	90	4	88	98
28	8.539	7,1	548	208	7,3	89	4	84	98
29	8.712								
30	8.592								
MED	9.242	7,3	741	270	7,5	90	10	88	96
MIN	7.697	7,0	533	106	7,1	72	4	81	93
MAX	10.712	7,5	942	440	7,9	154	23	92	98
TOTAL	277.274	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Junio'12



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.583								
2	6.413								
3	6.575	7,7	444	300	7,4	77	12	83	96
4	5.889	7,7	466	260	8,0	86	6	82	98
5	6.367	7,6	726	150	7,7	82	7	89	96
6	6.237	7,5	764	172	7,7	84	4	89	97
7	6.086	7,7	474	79	7,8	72	6	85	92
8	6.452								
9	6.881								
10	6.543	7,5	540	240	7,9	42	12	92	95
11	5.968	7,7	555	220	7,9	78	21	86	91
12	5.808								
13	5.925	7,6	578	206	7,9	70	37	88	82
14	5.731	7,4	697	225	7,7	72	36	90	84
15	6.453								
16	6.724								
17	6.854	7,4	875	260	7,5	80	18	91	93
18	6.093	7,4	868	280	7,5	87	15	90	95
19	6.607	7,2	660	260	7,5	83	7	87	97
20	6.128	7,5	689	280	6,9	101	14	85	95
21	5.652	7,3	607	82	7,1	111	14	82	83
22	6.161								
23	8.223								
24	7.396	7,6	756	340	7,8	80	15	89	96
25	7.098	7,4	912	380	7,3	87	16	90	96
26	7.473	7,4	622	232	7,9	88	9	86	96
27	7.491	7,3	585	214	7,2	86	7	85	97
28	7.735	7,6	600	127	7,7	76	3	87	98
29	7.722								
30	7.997								
MED	6.609	7,5	654	227	7,6	81	14	87	93
MIN	5.583	7,2	444	79	6,9	42	3	82	82
MAX	8.223	7,7	912	380	8,0	111	37	92	98
TOTAL	198.265	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Junio'12

