


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.048	7,2	726	200	7,4	102	15	86	93
2	12.091	7,3	563	220	7,2	71	10	87	95
3	12.244	7,2	466	217	6,9	83	7	82	97
4	10.006								
5	10.679								
6	10.816								
7	11.903								
8	8.944	7,6	667	320	7,6	92	17	86	95
9	9.692	7,4	867	520	7,5	93	16	89	97
10	9.538	7,3	681	185	7,4	114	38	83	79
11	9.490	7,3	689	260	7,7	114	25	83	90
12	8.990	7,4	600	232	7,5	117	14	80	94
13	9.408								
14	10.049								
15	8.285	7,2	719	340	7,5	84	12	88	96
16	8.449	7,3	652	500	7,4	102	42	84	92
17	8.797	7,7	510	169	7,5	101	19	80	89
18	8.293	7,5	867	219	7,9	98	14	89	94
19	8.977	7,3	548	171	7,4	90	9	84	95
20	8.965								
21	8.454								
22	8.238	7,3	592	360	7,2	92	3	85	99
23	9.156	7,3	808	280	7,5	102	28	87	90
24	9.147	7,5	444	200	7,2	95	13	79	94
25	9.399	7,3	756	244	7,2	86	16	89	93
26	9.232	7,7	667	210	7,1	75	7	89	97
27	9.216								
28	10.190								
29	12.014	7,5	615	240	7,2	69	7	89	97
30	11.798								
MED	9.750	7,4	654	268	7,4	94	16	85	93
MIN	8.238	7,2	444	169	6,9	69	3	79	79
MAX	12.244	7,7	867	520	7,9	117	42	89	99
TOTAL	292.507	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Abril'12



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.493	7,4	816	360	7,6	91	11	89	97
2	6.887	7,2	704	240	7,3	80	18	89	92
3	8.882	7,7	488	208	7,0	76	7	85	97
4	5.867								
5	7.214								
6	9.474								
7	9.667								
8	6.660	7,2	704	260	7,0	118	23	83	91
9	6.472	7,4	526	240	7,2	95	21	82	91
10	4.704	7,5	526	177	7,0	81	7	85	96
11	4.758	7,5	548	233	7,3	66	7	88	97
12	4.622	7,6	392	188	7,3	63	6	84	97
13	4.922								
14	5.678								
15	4.863	7,4	407	200	7,0	43	10	90	95
16	5.205	7,4	593	220	7,4	60	20	90	91
17	5.317	7,4	526	185	7,7	67	5	87	97
18	5.051	7,6	585	200	7,9	70	4	88	98
19	5.304	7,3	481	200	7,2	63	4	87	98
20	4.915								
21	5.670								
22	5.484	7,4	779	240	7,4	82	19	90	92
23	5.323	7,6	540	240	7,7	65	34	88	86
24	5.078	7,6	399	171	7,2	68	7	83	96
25	4.954	7,5	369	114	7,4	65	4	82	96
26	4.555	7,1	481	164	7,3	69	7	86	96
27	5.336								
28	10.843								
29	7.734	7,2	570	200	7,4	84	6	85	97
30	5.926								
MED	6.095	7,4	549	213	7,3	74	12	86	95
MIN	4.555	7,1	369	114	7,0	43	4	82	86
MAX	10.843	7,7	816	360	7,9	118	34	90	98
TOTAL	182.858	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Abril'12

