


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	11.484								
2	9.584								
3	11.307								
4	9.837	7,2	585	240	7,3	62	28	89	88
5	11.913	7,1	555	220	7,6	50	10	91	95
6	12.276	7,2	563	274	7,1	65	9	88	97
7	12.408	7,2	503	145	7,3	75	11	85	92
8	11.942	7,6	592	85	7,6	59	5	90	94
9	13.076								
10	13.278								
11	13.235	7,9	519	360	6,8	246	48	53	87
12	10.563	7,5	555	280	7,5	226	50	59	82
13	9.723	7,4	696	307	7,5	212	67	70	78
14	9.796	7,2	852	382	7,5	194	47	77	88
15	9.761	7,3	852	391	7,4	187	56	78	86
16	9.351								
17	11.879								
18	9.909	7,4	339	160	7,3	124	18	63	89
19	9.549	7,5	585	260	7,4	169	30	71	88
20	9.446	7,5	793	456	7,6	153	44	81	90
21	9.632	7,4	555	323	7,6	118	23	79	93
22	9.399	7,4	734	333	7,2	98	11	87	97
23	9.951								
24	9.122								
25	8.546	7,5	808	400	7,7	87	16	89	96
26	9.206	7,4	808	300	7,7	81	7	90	98
27	9.159	7,6	750		7,7	56		93	
28	9.430	7,7	666		7,5	51		92	
29	8.544	7,8	681		7,1	78		89	
30	9.814								
MED	10.437	7,4	650	289	7,4	120	28	81	90
MIN	8.544	7,1	339	85	6,8	50	5	53	78
MAX	13.278	7,9	852	456	7,7	246	67	93	98
TOTAL	313.125	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Noviembre'12



	Caudal entrada	AGUA BRUTA			AGUA TRATADA				REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH		D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-		mg/l	mg/l	%	%
1	5.796									
2	9.715									
3	9.622									
4	8.552	7,4	570	160	7,0	1.463,0	56	15	90	90
5	7.625	7,6	399	200	7,6	1.711,8	30	9	92	95
6	10.955	7,2	332	78	7,3	1.342,3	52	5	84	93
7	12.454	7,4	407	58	7,6	828,7	58	4	86	94
8	13.587	7,6	280	41	8,0	834,1	49	2	83	94
9	12.941									
10	11.285									
11	6.938	7,6	374	160	7,2	1.617,5	63	9	83	94
12	5.514	7,6	518	200	7,5	1.824,0	76	10	85	95
13	5.250	7,5	459	205	7,6	2.110,1	61	5	87	98
14	5.184	7,6	548	191	7,7	2.564,8	68	7	88	96
15	5.026	7,8	444	86	7,4	2.888,1	76	7	83	91
16	8.098									
17	10.326									
18	6.369	7,5	340	180	7,4	1.698,2	45	9	87	95
19	4.923	7,7	369	220	7,7	1.857,7	64	9	83	96
20	4.598	7,7	667	378	8,0	1.875,7	67	12	90	97
21	8.089	7,7	317	89	7,7	1.320,2	52	5	84	94
22	5.372	7,7	771	195	7,2	1.635,3	50	4	94	98
23	4.742									
24	4.298									
25	4.685	7,9	347	260	8,0	1.939,7	80	7	77	97
26	4.420	7,5	332	220	7,9	1.679,0	53	7	84	97
27	4.153	7,3	250		7,7	1.670,0	28		89	
28	3.948	7,7	144		7,6	1.650,0	33		77	
29	4.265	7,5	577		7,6	1.745,0	58		90	
30	4.427									
MED	7.105	7,6	422	172	7,6	1.712,8	56	8	86	95
MIN	3.948	7,2	144	41	7,0	828,7	28	2	77	90
MAX	13.587	7,9	771	378	8,0	2.888,1	80	15	94	98
TOTAL	213.157	-	-	-	-		-	-	-	-

Rendimientos EDAR La Barrosa - Noviembre'12

