


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	11.080								
2	10.004	7,2	852	440	7,1	92	29	89	93
3	10.221	7,2	659	280	7,7	93	7	86	98
4	9.072	7,0	778	288	8,0	99	9	87	97
5	8.707	7,2	689	225	8,2	96	10	86	96
6	9.344	7,4	637	181	8,1	95	12	85	93
7	9.236								
8	7.701								
9	8.747	7,5	748	480	8,5	139	12	81	98
10	9.003	7,4	741	320	8,5	99	13	87	96
11	7.784	7,5	882	294	8,5	98	13	89	96
12	8.647	7,4	696	236	7,5	87	13	87	94
13	11.243	7,5	875	294	8,0	96	12	89	96
14	6.671								
15	9.068								
16	7.380	7,4	800	520	7,8	92	20	89	96
17	10.396	7,5	696	340	8,0	81	10	88	97
18	8.147	7,4	793	333	8,0	81	11	90	97
19	8.880	7,3	830	389	8,1	92	11	89	97
20	8.684	7,5	711	240	7,8	90	13	87	95
21	8.680								
22	9.040								
23	7.800	7,7	689	360	7,3	83	13	88	96
24	6.705	7,5	734	380	7,8	84	13	89	97
25	10.686	6,9	689	400	8,1	77	9	89	98
26	8.721	7,2	905	400	8,0	89	5	90	99
27	9.935	7,2	852	288	7,4	81	10	90	97
28	9.988								
29	9.818								
30	7.859	7,3	726	440	8,1	69	10	90	98
31	9.787								
MED	9.001	7,3	761	339	7,9	91	12	88	96
MIN	6.671	6,9	637	181	7,1	69	5	81	93
MAX	11.243	7,7	905	520	8,5	139	29	90	99
TOTAL	279.034	-	-	-	-	-	-	-	-

## Rendimientos EDAR El Torno - Marzo'14



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	3.784								
2	3.779	7,7	712	320	7,2	86	9	88	97
3	3.579	7,9	451	200	7,2	72	24	84	88
4	3.678	7,1	548	141	7,9	43	2	92	99
5	3.789	7,3	488	133	7,0	66	3	86	98
6	3.599	7,6	503	123	7,6	65	3	87	98
7	3.409								
8	3.765								
9	3.500	7,7	563	240	7,3	75	18	87	93
10	4.605	7,5	474	220	7,3	95	9	80	96
11	3.624	7,7	660	157	6,9	90	5	86	97
12	3.718	7,7	607	222	6,9	83	9	86	96
13	3.789	7,9	488	94	7,7	66	4	86	95
14	3.808								
15	3.892								
16	3.652	7,7	518	240	6,5	59	16	89	94
17	3.853	7,5	578	300	6,5	76	16	87	95
18	3.836	7,7	689	161	7,0	77	4	89	97
19	3.556	7,1	756	135	7,0	80	5	89	97
20	3.735	7,6	570	161	7,7	81	6	86	97
21	3.601								
22	4.010								
23	3.697	7,3	667	340	7,6	68	8	90	98
24	3.721	7,3	660	300	7,4	75	10	89	97
25	3.657	7,1	555	280	7,1	67	13	88	95
26	3.794	7,3	555	200	7,4	59	7	89	96
27	4.652	7,4	540	185	7,3	87	13	84	93
28	7.257								
29	6.704								
30	4.815	7,5	734	320	6,9	75	12	90	96
31	4.299								
MED	4.037	7,5	587	213	7,2	74	9	87	96
MIN	3.409	7,1	451	94	6,5	43	2	80	88
MAX	7.257	7,9	756	340	7,9	95	24	92	99
TOTAL	125.157	-	-	-	-	-	-	-	-

## Rendimientos EDAR La Barrosa - Marzo'14

