


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	1.779								
2	2.247	7,8	838	460	8,3	87	17	90	96
3	2.791	7,7	867	320	7,9	95	13	89	96
4	2.646	7,6	726	262	8,2	81	11	89	96
5	2.622	7,4	510	150	7,5	69	6	86	96
6	2.522	7,2	756	167	7,2	81	7	89	96
7	2.670								
8	2.489								
9	2.567	7,6	548	160	7,6	84	8	85	95
10	2.582	7,5	711	240	7,8	90	24	87	90
11	2.511	7,2	778	222	7,6	71	9	91	96
12	2.559	7,2	741	183	7,4	93	6	87	97
13	2.424	7,2	607	154	7,5	83	8	86	95
14	2.625								
15	2.478								
16	2.632	7,2	771	160	7,3	72	8	91	95
17	2.489	7,6	823	400	8,0	66	8	92	98
18	2.623	7,5	897	259	7,2	80	8	91	97
19	2.196	7,4	719	202	7,5	80	7	89	97
20	2.265	7,6	518	150	7,8	86	8	83	95
21	2.921								
22	2.589								
23	2.616	7,4	681	220	7,7	89	22	87	90
24	2.866	7,3	711	420	7,8	96	10	86	98
25	2.514	7,4	577	183	7,5	66	6	88	97
26	2.365	7,6	696	223	7,9	89	8	87	96
27	2.453								
28	2.221								
MED	9.955	7,4	709	239	7,7	82	10	88	95
MIN	8.222	7,2	510	150	7,2	66	6	83	90
MAX	13.057	7,8	897	460	8,3	96	24	92	98
TOTAL	278.749	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Febrero'14



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.358								
2	3.516	8,0	756	340	7,9	80	14	89	96
3	6.342	7,8	726	320	7,7	75	15	90	95
4	3.613	7,7	630	99	7,8	66	3	90	97
5	8.730	7,4	377	128	7,6	76	3	80	98
6	5.617	7,4	392	71	7,4	67	2	83	97
7	4.872								
8	8.223								
9	12.702	7,6	540	200	7,7	71	13	87	93
10	6.906	7,6	570	200	7,7	80	17	86	92
11	6.058	8,0	384	69	7,5	45	3	88	96
12	6.316	7,2	779	114	7,3	79	2	90	98
13	4.293	7,3	474	74	6,9	81	4	83	95
14	4.913								
15	6.068								
16	4.089	7,1	697	220	7,4	68	17	90	92
17	3.906	7,7	355	160	7,7	48	10	87	94
18	3.851	7,5	511	108	7,1	74	4	85	96
19	3.605	7,4	414	113	7,1	60	4	86	97
20	3.788	7,5	377	69	7,3	83	5	78	93
21	4.194								
22	4.268								
23	5.253	7,6	555	200	7,3	77	8	86	96
24	4.958	7,4	407	240	7,6	48	17	88	93
25	3.622	7,6	407	83	7,1	47	2	88	98
26	3.285	7,6	578	123	7,0	83	2	86	98
27	3.515								
28	4.067								
MED	5.176	7,5	522	154	7,4	69	8	86	95
MIN	3.285	7,1	355	69	6,9	45	2	78	92
MAX	12.702	8,0	779	340	7,9	83	17	90	98
TOTAL	144.928	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Febrero'14

