


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.975	7,3	994	439	8,0	80	6	92	99
2	7.987	7,4	734	303	8,1	65	10	91	97
3	8.326								
4	8.177								
5	7.534	7,2	681		8,2	77		89	
6	7.976	7,0	734		7,5	72		90	
7	8.175	7,6	880		7,5	47		95	
8	8.085	7,7	750		7,5	77		90	
9	8.183								
10	8.747								
11	9.545	7,9	460		7,6	44		90	
12	9.663	7,8	548		7,5	43		92	
13	8.571	7,9	560		7,5	42		92	
14	8.484	7,9	560		7,5	42		92	
15	8.145								
16	8.207								
17	8.277	7,5	666		7,2	74		89	
18	8.000	7,2	723		7,3	139		81	
19	7.299	7,9	641		7,4	57		91	
20	7.808	7,4	634		7,7	108		83	
21	7.964	7,2	714		7,2	67		91	
22	7.856								
23	7.730								
24	7.850	7,4	737		7,5	55			
25	7.711	7,9	670		7,4	44		93	
26	6.921	7,9	670		7,4	55		93	
27	7.765	7,9	670		7,4	55		92	
28	7.621	7,4	637	400	7,6	55	10	91	98
29	7.786	7,5	637	380	7,8	62	15	90	96
30	8.082	7,1	845	466	7,9	84	5	90	99
31	7.800								
MED	8.073	7,5	688	398	7,6	66	9	90	98
MIN	6.921	7,0	460	303	7,2	42	5	81	96
MAX	9.663	7,9	994	466	8,2	139	15	95	99
TOTAL	250.250	-	-	-	-	-	-	-	-

## Rendimientos EDAR El Torno - Octubre'14



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.624	7,5	875	308	7,3	72	4	92	99
2	5.516	7,7	555	303	7,6	60	9	89	97
3	5.653								
4	6.462								
5	6.173	7,5	607		7,1	62		90	
6	5.552	7,3	533		7,4	66		88	
7	6.029	7,7	390		7,3	36		91	
8	5.902	7,6	446		7,4	32		93	
9	5.986								
10	9.675								
11	7.313	7,8	436		7,5	26		94	
12	6.961	7,7	1.080		7,3	27		97	
13	8.423	7,8	529		7,2	30		94	
14	6.033	7,8	529		7,2	30		94	
15	4.932								
16	4.995								
17	5.231	7,4	433		7,2	23		95	
18	5.621	7,2	279		7,3	23		92	
19	5.264	7,8	499		7,6	25		95	
20	5.168	7,2	300		7,4	30		90	
21	4.967	7,3	609		7,2	28		95	
22	5.015								
23	5.192								
24	5.148								
25	5.498	7,1	334		7,5	23		93	
26	5.221	7,5	675		7,4	22		97	
27	4.693	7,5	642		7,4	59		91	
28	4.438	7,5	667	380	7,4	65	11	90	97
29	4.556	7,4	533	320	7,5	52	8	90	98
30	4.500	7,7	808	324	7,1	71	3	91	99
31	#¡REF!								
MED	#¡REF!	7,5	560	327	7,3	41	7	92	98
MIN	#¡REF!	7,1	279	303	7,1	22	3	88	97
MAX	#¡REF!	7,8	1.080	380	7,6	72	11	97	99
TOTAL	#¡REF!	-	-	-	-	-	-	-	-

## Rendimientos EDAR La Barrosa - Junio'12

