


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.245								
2	8.640								
3	8.234	7,6	771	360	8,0	89	28	88	92
4	9.038	7,5	845	440	7,6	93	12	89	97
5	8.082	7,5	800	358	7,7	86	21	89	94
6	9.232	7,4	882	310	7,2	89	18	90	94
7	8.354	7,3	629	501	7,3	86	37	86	93
8	8.532								
9	8.590								
10	7.773	7,4	681		7,4	93		86	
11	10.085	7,4	786	400	7,4	96	10	88	98
12	9.379	7,4	979	600	7,7	96	8	90	99
13	9.306	7,0	882	354	7,0	96	6	89	98
14	7.906	7,4	964	654	7,4	96	4	90	99
15	8.310								
16	7.817								
17	7.667	7,5	957	600	7,4	95	34	90	94
18	8.822	7,3	392		7,0	98		75	
19	10.812	7,5	590		7,3	83		86	
20	9.486	7,4	949	360	7,3	89	12	91	97
21	8.368	7,4	830	388	7,5	84	21	90	95
22	11.522								
23	12.669								
24	9.350	7,5	875	360	7,3	68	27	92	93
25	10.076	7,2	652	360	7,2	77	4	88	99
26	9.015	7,3	882	542	7,0	89	17	90	97
27	8.912								
28	10.997	7,4	533	158	7,0	84	10	84	94
MED	9.115	7,4	783	422	7,3	89	17	88	96
MIN	7.667	7,0	392	158	7,0	68	4	75	92
MAX	12.669	7,6	979	654	8,0	98	37	92	99
TOTAL	255.218	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Febrero'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	3.734								
2	3.769								
3	3.788	7,6	488	220	7,6	69	9	86	96
4	3.836	7,9	853	320	8,0	65	8	92	97
5	3.428	7,6	392	159	7,9	56	10	86	94
6	3.796	7,6	622	234	7,1	54	6	91	97
7	3.470	7,5	518	342	7,3	63	11	88	97
8	3.755								
9	3.888								
10	4.033	7,4	414		7,4	65		84	
11	4.243	8,0	407	260	7,3	58	15	86	94
12	3.969	7,7	704	280	8,0	61	6	91	98
13	4.119	7,2	511	215	6,9	44	7	91	97
14	3.687	7,6	384	171	7,6	62	5	84	97
15	3.830								
16	3.977								
17	3.975	7,9	295	180	7,4	74	17	75	90
18	8.011	7,1	202			46		77	
19	8.267	7,7	183			15		92	
20	4.842	7,5	607	220	7,5	67	7	89	97
21	5.867	7,8	481	166	7,9	69	10	86	94
22	11.024								
23	5.965								
24	4.514	7,6	340	200	7,3	49	13	85	93
25	4.209	7,5	280	140	7,2	33	12	88	91
26	4.481	7,9	273	108	6,9	42	6	85	94
27	6.687								
28	5.442	7,3	481	202	7,3	57	9	88	96
MED	4.807	7,6	444	214	7,4	55	10	87	95
MIN	3.428	7,1	183	108	6,9	15	5	75	90
MAX	11.024	8,0	853	342	8,0	74	17	92	98
TOTAL	134.606	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Febero'13

