


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.693	7,5	957	360	7,6	87	25	91	93
2	8.327	7,1	964	599	7,4	86	12	91	98
3	9.288								
4	8.379								
5	8.288	7,0	919	660	7,4	89	16	90	98
6	8.905	7,1	726	600	7,8	84	29	88	95
7	9.183	7,3	890	526	7,6	75	8	92	98
8	8.941	7,1	875	374	7,0	74	5	92	99
9	8.993	7,3	919	369	7,4	69	6	92	98
10	8.397								
11	9.240								
12	7.581	7,5	949	580	7,6	75	25	92	96
13	8.978	7,3	888	680	7,8	72	18	92	97
14	9.173	7,3	994	479	7,4	84	13	92	97
15	8.005	7,2	808	356	7,4	78	13	90	96
16	8.499	7,3	726	441	7,2	99	24	86	95
17	10.927								
18	8.872								
19	8.024	7,3	756	560	7,3	81	17	89	97
20	8.760	7,3	1.083	560	7,6	90	12	92	98
21	9.195	7,3	815	391	7,5	84	8	90	98
22	8.843	7,3	622	283	7,4	81	14	87	95
23	9.070	7,2	800	445	7,3	87	16	89	96
24	9.001								
25	8.616								
26	7.384	7,4	815	380	7,3	77	39	91	90
27	9.609	7,5	875	560	7,7	71	28	92	95
28	5.932	7,4	1.038	452	7,7	92	17	91	96
29	9.099	7,3	726	341	7,6	84	19	88	94
30	8.472	7,1	964	371	7,3	78	16	92	96
31	9.394								
MED	8.680	7,3	869	471	7,5	82	17	90	96
MIN	5.932	7,0	622	283	7,0	69	5	86	90
MAX	10.927	7,5	1.083	680	7,8	99	39	92	99
TOTAL	269.065	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Mayo'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.855	7,8	511	220	7,7	66	16	87	93
2	6.086	7,4	451	169	7,4	60	7	87	96
3	6.240								
4	6.809								
5	6.235	7,2	726	440	7,6	73	23	90	95
6	5.561	7,3	526	340	7,5	72	21	86	94
7	6.045	7,6	563	271	7,8	68	10	88	96
8	5.130	7,2	548	209	7,3	44	5	92	98
9	6.287	7,3	466	191	7,7	65	6	86	97
10	5.775								
11	6.865								
12	6.298	7,7	622	360	7,9	73	15	88	96
13	5.474	7,6	712	320	7,9	63	18	91	94
14	5.916	7,6	600	285	7,5	55	9	91	97
15	6.042	7,4	548	170	7,5	58	8	89	96
16	5.591	7,4	615	230	7,4	60	9	90	96
17	6.296								
18	5.718								
19	5.754	7,2	526	220	7,1	106	38	80	83
20	5.464	7,3	689	320	7,6	73	16	89	95
21	5.402	7,2	533	177	7,8	61	12	89	93
22	5.505	7,6	615	185	7,7	69	7	89	96
23	6.135	7,5	466	210	7,6	66	12	86	94
24	5.725								
25	6.263								
26	6.271	7,5	548	180	7,3	66	16	88	91
27	5.728	7,5	704	260	7,6	72	23	90	91
28	6.244	7,7	630	216	7,9	65	6	90	97
29	5.978	7,7	607	280	7,6	73	12	88	96
30	6.104	7,8	793	310	7,2	80	11	90	96
31	6.671								
MED	5.983	7,5	591	253	7,6	68	14	88	95
MIN	5.130	7,2	451	169	7,1	44	5	80	83
MAX	6.865	7,8	793	440	7,9	106	38	92	98
TOTAL	185.467	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Mayo'13

