


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.400								
2	8.110								
3	8.363	7,4	927	480	7,5	96	22	90	95
4	9.932	7,3	897	540	7,4	92	25	90	95
5	11.372	7,1	600	213	7,2	93	22	84	90
6	12.301	7,4	882	458	7,2	89	5	90	99
7	11.337	7,1	644	315	7,0	77	18	88	94
8	10.454								
9	12.470								
10	8.105	7,5	912	500	7,1	89	24	90	95
11	11.640	8,2	354	185	7,8	55	6	84	97
12	12.180								
13	11.199	7,5	971	360	7,7	71	5	93	99
14	9.829	7,7	912	219	7,6	93	20	90	91
15	9.835								
16	8.980								
17	8.632	7,4	778	540	7,4	92	15	88	97
18	8.999	7,5	1.128	800	7,5	105	8	91	99
19	9.024	7,8	1.096		7,5	53		95	
20	9.221	7,4	756	350	7,3	107	9	86	97
21	8.478	7,6	964	546	7,2	114	7	88	99
22	9.313								
23	10.358								
24	11.445	7,4	800	400	8,1	87	25	89	94
25	9.926	7,3	1.128	600	7,7	83	13	93	98
26	9.340	7,3	905	576	7,8	66	13	93	98
27	10.144								
28	11.825								
29	9.465								
30	11.102								
31	8.752	7,5	763	380	7,7	89	24	88	94
MED	10.049	7,5	856	439	7,5	86	15	89	96
MIN	8.105	7,1	354	185	7,0	53	5	84	90
MAX	12.470	8,2	1.128	800	8,1	114	25	95	99
TOTAL	311.529	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Marzo'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.740								
2	4.658								
3	4.394	7,5	407	240	7,6	62	12	85	95
4	9.149	7,6	258	180	7,6	66	11	75	94
5	8.404	7,5	250	97	7,5	62	9	75	91
6	10.028	7,6	317	131	7,4	39	5	88	96
7	10.314	7,2	288	79	7,2	43	7	85	91
8	6.275								
9	5.624								
10	6.438	7,5	459	200	7,2	68	10	85	95
11	11.069	7,5	88	45	7,4	23	7	74	84
12	11.148								
13	7.401	8,0	250	140	7,9	50	8	80	94
14	5.691	8,0	384	143	8,0	62	6	84	96
15	5.289								
16	4.858								
17	5.723	7,5	317	160	7,6	61	15	81	90
18	4.609	7,7	221	160	7,8	52	10	76	94
19	7.940	7,5	304		7,3	38	24	88	
20	5.266	7,5	392	74	7,5	60	6	85	92
21	5.458	7,9	421	103	7,6	56	7	87	93
22	4.948								
23	10.689								
24	7.229	7,4	615	380	7,9	72	13	88	97
25	6.270	7,5	362	220	7,7	63	18	83	92
26	6.419	7,6	600	256	7,5	70	7	88	97
27	7.930								
28	10.820								
29	10.648								
30	10.577								
31	9.306	7,7	340	380	7,9	114	8	67	98
MED	7.397	7,6	348	176	7,6	59	10	82	93
MIN	4.394	7,2	88	45	7,2	23	5	67	84
MAX	11.148	8,0	615	380	8,0	114	24	88	98
TOTAL	229.312	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Marzo'13

