

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.418	7,4	897	400	7,6	80	10	91	98
2	10.771	7,4	871	325	7,4	74	13	92	96
3	10.784	7,3	1.207	392	7,3	50	12	96	97
4	10.474	7,3	992	293	7,3	88	11	91	96
5	10.950								
6	10.333								
7	9.638	6,7	2.173	540	7,3	61	5	97	99
8	10.442	7,1	1.640	540	7,6	61	7	96	99
9	10.566	7,1	863	331	7,6	54	8	94	98
10	9.870	7,2	682	300	7,4	43	11	94	96
11	9.959	7,0	897	364	7,4	71	13	92	96
12	10.609								
13	10.261								
14	9.452	6,8	1.984	560	7,3	59	8	97	99
15	10.629	7,0	1.485	420	7,2	81	18	95	96
16	10.118	7,1	389	215	7,3	47	7	88	97
17	10.645	7,0	854	250	7,1	49	7	94	97
18	10.457	7,1	975	279	7,2	68	3	93	99
19	9.774								
20	10.506								
21	9.770	7,0	889	360	7,0	92	12	90	97
22	10.578	7,5	871	340	7,5	49	12	94	96
23	9.992	7,3	958	330	7,5	62	9	94	97
24	10.353	7,0	880	413	6,9	49	12	94	97
25	10.536	7,2	1.035	433	7,2	78	15	92	97
26	9.890								
27	10.274								
28	9.827	6,8	863	200	7,1	61	5	93	98
29	9.821	7,0	1.259	440	7,1	64	15	95	97
30	9.665	7,4	1.138	417	7,5	73	7	94	98
31	9.926	7,0	870	319	7,4	56	8	94	97
MED	10.203	7,1	1.073	368	7,3	64	10	93	97
MIN	9.418	6,7	389	200	6,9	43	3	88	96
MAX	10.950	7,5	2.173	560	7,6	92	18	97	99
TOTAL	316.288	-	-	-	-	-	-	-	-