


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.835								
2	7.507	7,1	470	139	7,8	22	8	95	94
3	7.507	7,0	720	176	7,2	15	5	98	97
4	8.158	7,1	680	155	7,2	15	5	98	97
5	8.056	7,1	390	100	7,1	15	5	96	95
6	8.244	7,6	375	102	7,0	15	5	96	95
7	8.683								
8	8.500								
9	7.838	7,1	500	112	7,5	15	5	97	96
10	8.173	7,1	450	134	7,4	15	5	97	96
11	8.522	7,0	455	114	7,7	17	6	96	95
12	8.260	7,1	315	72	7,5	40	11	87	85
13	8.554	7,0	300	61	7,3	34	7	89	88
14	8.649								
15	8.619								
16	7.427	7,2	554	360	7,5	37	9	93	98
17	8.339	7,2	575	380	7,4	40	7	93	98
18	8.506	7,2	757	316	7,4	40	3	95	99
19	8.360	7,0	837	246	7,4	63	9	92	96
20	8.606	7,4	757	233	7,6	40	2	95	99
21	9.141								
22	7.692								
23	8.050	7,2	697	400	7,3	38	11	95	97
24	8.494	7,1	539	360	7,5	34	7	94	98
25	8.864	7,0	639	269	7,2	30	6	95	98
26	8.766	7,2	735	250	7,4	43	1	94	100
27	9.194	7,2	678	172	7,6	44	2	93	99
28	9.007								
29	8.453								
30	7.784	7,5	528	380	7,6	34	7	94	98
31	8.464	7,1	876	420	7,4	38	16	96	96
MED	8.331	7,2	583	225	7,4	31	6	94	96
MIN	7.427	7,0	300	61	7,0	15	1	87	85
MAX	9.194	7,6	876	420	7,8	63	16	98	100
TOTAL	258.252	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Julio'17



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.859								
2	8.305	7,1	790	215	7,4	24	5	97	98
3	9.228	7,2	285	53	7,2	15	5	95	91
4	9.130	7,3	700	167	7,1	15	5	98	97
5	9.091	7,1	490	101	7,1	15	5	97	95
6	9.466	7,1	1.000	207	7,3	15	5	99	98
7	9.404								
8	9.484								
9	10.068	7,1	200	49	7,3	15	5	93	90
10	10.653	7,2	200	58	7,1	15	5	93	91
11	9.738	7,1	230	45	7,2	15	5	93	89
12	9.819	7,2	220	46	7,4	18	6	92	86
13	9.883	7,1	340	81	7,0	42	9	88	89
14	10.296								
15	10.311								
16	11.326	7,2	756	420	7,7	40	12	95	97
17	11.954	7,3	774	360	7,3	37	8	95	98
18	11.064	7,3	815	275	7,4	45	4	94	99
19	11.066	7,2	602	176	7,2	45	3	93	99
20	10.681	7,4	805	256	7,5	45	4	94	99
21	10.761								
22	10.758								
23	11.571	7,2	1.113	640	7,3	50	20	96	97
24	12.201	7,2	1.132	480	7,5	37	7	97	99
25	11.227	7,1	489	154	7,1	46	14	91	91
26	10.828	7,3	657	130	7,2	47	2	93	98
27	10.405	7,3	845	92	7,7	48	1	94	99
28	11.065								
29	10.655								
30	10.687	7,4	472	380	7,5	68	24	86	94
31	10.332	7,4	507	360	7,6	47	16	91	96
MED	10.301	7,2	610	216	7,3	34	8	94	95
MIN	7.859	7,1	200	45	7,0	15	1	86	86
MAX	12.201	7,4	1.132	640	7,7	68	24	99	99
TOTAL	319.316	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Julio'17

